

ADDITIONAL AGENDA-1

FOR

35th MEETING OF COMMERCIAL SUB-COMMITTEE

ITEM-AA1. Petition filed by SJVNL in CERC regarding consideration of declared capacity of Nathpa Jhakri Hydro Power Station (6X250 MW) and Rampur Hydro Power Station (6X68.67 MW) corresponding to installed capacity including overload capacity in accordance with Regulation 6.5 (12) of Indian Electricity Grid Code ,2010.

SJVNL has filed a petition in CERC on 05.02.2016 regarding consideration of declared capacity of Nathpa Jhakri Hydro Power Station (6X250 MW) and Rampur Hydro Power Station (6X68.67 MW) corresponding to installed capacity including overload capacity in accordance with Regulation 6.5 (12) of Indian Electricity Grid Code ,2010. The petition is available on SJVNL web site at the link <http://sjvn.nic.in/writereaddata/Portal/Tariff/71/petition.pdf>.

In the petition SJVNL has mentioned that NRLDC vide letter dated 29.04.2017 informed that the generator shall ensure that the DC on bar does not exceed the capacity on bar less normative auxiliary consumption. In case the generator gives the DC value higher than this figure , the same shall be restricted to the capacity on bar less normative auxiliary consumption. For relaxation under spillage condition an undertaking is to be given by the generator to NRLDC.

SJVNL has submitted that this action by NRLDC is in contrary to provisions of Regulation 6.5 (12) of IEGC,2010, which provides that “Maximum capacity of the station declared for the day shall be equal to the installed capacity including overload capability, if any, minus auxiliary consumption, corrected for the reservoir level”.

SJVNL has also submitted that as per REA , DC of some stations is more than Ex-bus installed capacity in some stations in NR , ER and NER.

SJVNL has prayed CERC to declare that stand taken by NRLDC to restrict the DC to Ex-bus installed capacity without considering the over-load capacity, is contrary to IEGC and to direct NRLDC & NRPC to revise the DC/ PAF in REA w.e.f. May,2017.

The detailed submission by SJVNL in the petition is available on SJVNL web site.

Members may discuss.