



सत्यमेव जयते

भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
उत्तर क्षेत्रीय विद्युत समिति
Northern Regional Power Committee

No: NRPC/OPR/106/01/2018/2893-2933

Dated: 28.02.2018

विषय: प्रचालन समन्वय उपसमिति की 144 वीं बैठक में स्वीकृत आऊटेज कार्यक्रम की सूची
-शुद्धिपत्र

Subject: Outage programme approved in 144th OCC meeting-Corrigendum

Please refer to this office letter of even no dated 23.2.2018 regarding the subject cited above

The amended outages are enclosed with.

-sd-

अधीक्षण अभियंता(प्रचालन)

सेवा में,
प्रचालन समन्वय उप-समिति के सदस्य

OUTAGES APPROVED AS PER LETTER DATED 23.2.18

3	NRSXXIX	NRSXXIX	JALANDHAR-SAMBA CKT I	DAILY	AMP WORKS	22.3.18	8:00	22.3.18	18:00	
---	---------	---------	-----------------------	-------	-----------	---------	------	---------	-------	--

312	STERLITE TECHNOOGIES LIMITED	STERLITE TECHNOOGIES LIMITED GPTL/NRSXXIX	LINE	DHANONDA (400KV)(HVPNL)- DAULTABAD (400KV)(HVPNL) 1	DAILY	for Line Crossing works of 400KV DC Neemrana- Dhanonda Line at 46/0-47/0	2018- 03-14	07:00	2018- 03-14	18:00
-----	------------------------------	--	------	--	-------	--	----------------	-------	----------------	-------

314	STERLITE TECHNOOGIES LIMITED	STERLITE TECHNOOGIES LIMITED GPTL/NRSXXIX	LINE	URI-1 (400KV)(NHPC)-WAGOORA (400KV)(POWERGRID) II	CONTINUOUS	For LILO of existing 400KV D/C Uri-Wagoora Line 1&2 at Amargarh 400/220KV Substation, Thus to Form 400KV D/C Amargarh-Uri I&II,Amargarh-Wagoora I&II, Including PLCC shifting from wagoora and recomissioning OCC approved the outage stating that work on one circuit at a time be done also the consent of NHPC & J&K will be required in real time.	2018- 03-01	08:00	2018- 03-08	18:00
315	STERLITE TECHNOOGIES LIMITED	STERLITE TECHNOOGIES LIMITED GPTL/NRSXXIX	LINE	URI-1 (400KV)(NHPC)-WAGOORA (400KV)(POWERGRID) I	CONTINUOUS	For LILO of existing 400KV D/C Uri-Wagoora Line 1&2 at Amargarh 400/220KV Substation, Thus to Form 400KV D/C Amargarh-Uri I&II,Amargarh-Wagoora I&II, Including PLCC shifting from wagoora and recomissioning OCC approved the outage stating that work on one circuit at a time be done also the consent of NHPC & J&K will be required in real time	2018- 03-01	08:00	2018- 03-08	18:00

THE ABOVE OUTAGES ARE AMMENDED TO BE READ AS ARE AS UNDER:

3	NRSXXIX	NRSXXIX	JALANDHAR-SAMBA CKT II	DAILY	AMP WORKS	22.3.18	8:00	22.3.18	18:00	
---	---------	---------	------------------------	-------	-----------	---------	------	---------	-------	--

312	STERLITE TECHNOOGIES LIMITED	STERLITE TECHNOOGIES LIMITED GPTL/NRSXXIX	LINE	DHANONDA (400KV)(HVPNL)- DAULTABAD (400KV)(HVPNL)	DAILY	For Line Crossing works of 400KV DC Neemrana-Dhanonda Line at 46/0-47/0 OCC approved the outage for the shutdown of the line for crossing work of 400KV DC Neemrana-Dhanonda subject to the restoration of CLP JHAJJAR-Dhanoda line and he consent of Haryana in real time	2018-03-14	07:00	2018-03-15	18:00
-----	------------------------------	--	------	--	-------	--	------------	-------	------------	-------

314	STERLITE TECHNOOGIES LIMITED	STERLITE TECHNOOGIES LIMITED GPTL/NRSXXIX	LINE	URI-1 (400KV)(NHPC)- WAGOORA (400KV)(POWERGRID) II	CONTINUOUS	For Carrying out the works 1. For Balance cross arm erection in AP10 tower, 2. Dismantlimng of existing CKT-2 Conductor between existing towers 168 and 170 3.stringing between AP10(New) and tower No.170 and required jumpering 4.stringing between AP9(New) and tower No.168 and required jumpering 5.PLCC shifting from Uri and commissioning 6.Relay settings modification at Uri and wagoora and testing 7.Chargimng of 400KV D/C Uri-wagoora CKt-2 as 400KV S/C Uri-Amargarh 2 and Amargarh-Wagoora OCC approved the outage stating that work on one circuit at a time be done also the consent of NHPC & J&K will be required in real time.	2018-03-03	08:00	2018-03-08	18:00
-----	------------------------------	--	------	---	------------	---	------------	-------	------------	-------

315	STERLITE TECHNOOGIES LIMITED	STERLITE TECHNOOGIES LIMITED GPTL/NRSXXIX	LINE	URI-1 (400KV)(NHPC)- WAGOORA (400KV)(POWERGRID) I	CONTINUOUS	For safety personnel during working on the same tower and due to existing high induction issues due to snowfall during execution of works for CKT-2 LILLO OCC approved the outage stating that work on one circuit at a time be done also the consent of NHPC & J&K will be required in real time	2018-03-03	08:00	2018-03-05	18:00
-----	------------------------------	--	------	---	------------	---	------------	-------	------------	-------

List for Operation Issues

Adani PL.	(i) Sh. Nirmal Sharma, VP (O&M), Fax- 0141-2292065 (ii) Sh. Sameer Ganju, Head-Northern Region, Fax No. 011-24115560
APCPL	(i) AGM (O&M)-I, IGSTPP, Fax No. 01251-266326 (ii) AGM (EEMG), 01251-266326
BBMB	(i) Director (PR) Fax- 0172-2652820 (ii) Power Controller, Fax- 0172-2653297.
HVPNL	Chief Engineer (Comm.); SE (SO & SLDC): 0181-2664440 Fax-0172-2560622
NHPC	(i) Sh. Janardan Choudhary, E.D., Faridabad – Fax-0129-2272413 (ii) Sh.V.K.Sinha, Chief Engineer (O&M), Faridabad – Fax-0129-2272413
POWERGRID	(i) Sh. Prabhakar Singh, ED (NR-I), Fax No. 011-26853488 (ii) Sh. A.K. Arora, General Manager (O&M), NR-I, (iii) Sh. R.V.S Kushwaha, General Manager (O&M), Jammu; Fax- 0191-2471187 (iv) Sh.Rajeev Sudan Dy, General Manager (OS), Fax- 0191-2471187
RRVUNL	Sh. P.S Arya, Chief Engineer (PPMC & IT),) Fax- 0141-2740006
NTPC	(i) Head of OS/ Head of RCC, Fax No. 0120-2410082 (ii) Sh. Praveen Chaturvedi, GM (OS), NRHQ Lucknow; Fax-0522-2305849.
HPSEBL	(i) Sh Suneel Grover, Chief Engineer (SO &P), Fax No. 0177-2653656 (ii) Sh. Deepak Uppal, SE (PR& ALDC): Fax-0177-2837143 (iii) Sh. Joginder Singh. Power Controller, Fax No. 0177-2837143.
NRLDC	General Manager - 26854861, 4051, 26569504 Fax- 26852747
NLDC	General Manager, NLDC, Fax: 011-26853488/26601079
Lanco APTL	Sh. Raj Kumar Roy, Director, Fax: 0124-2341627/4741024
SJVNL/NJHPS	General Manager (C&SO), Fax- 0177-2673283
PTCUL/UPCL	(i) Sh. Anupam Sharma, SE (SLDC), Fax- 0135-2451160, 0135-2763570
UPPTCL	(i) Director (Op), Fax- 0522-2286476 (ii) Chief Engineer (SLDC), Fax- 0522-2287880, 2288736
HPLDS	(i) Sh. N.P.sharma, SE, SLDC, Fax: 0177-2837649 (ii) Sh. Lokesh Thakur, Executive engineer, Fax: 0177-2837649
DTL	General Manager (SLDC)/ General Manager (Protection) Fax-23236462, 23221069
THDCIL	Sh. GM(EM - Design), Rishikesh
PSTCL	(i) Sh. S.S.Mal, Chief Engineer (SLDC) Fax – 0175-2365340 (ii) Sh D.P.Sethi, Dy.Chief Engineer (SLDC) Fax – 0175-2365340
CHANDIGARH	Sh. M.P.Singh, SE (Elect. Op.Circle) – Fax-0172-2740505
IPGCL/PPCL	(i) Sh. Y.P.Arora,GM (T), IPGCL, New Delhi, Fax- 23370884 (ii) Sh. R.K.Yadav, DGM (T), IPGCL, New Delhi, Fax- 23370884
BRPL	Sh. Satinder Sondhi, VP & Head System Operations, Fax No. 011-39996549
Everest PPL	Sh. Yogendra Kumar, Chief Operating Officer, Fax No. 011-45823862/ 43852507
RPSCCL	Sh. Niranjan Jena, Addl.VP/ Sh. Suwendu Dey, Asst. VP-O&M, Fax: 05842-300003
HPGCL	Sh. S.K. Wadhwa SE/Technical(HQ), Fax: 0172-5022436
CEA	(i) Sh.Vikram Singh, Director; Fax-26170385,26108834 (ii) Chief Engineer, NPC, New Delhi
HPPTCL	Director (Planning & Contracts), Fax: 0177-2626284
J&K (PDD)	Chief Engineer (Survey & Commercial) Fax-0191-2476213
J&K SPDCL	GM, Fax: 0194-2500145
PSPCL	Engineer-in- Chief (PPRR), Fax- 0175-2308698.
RRVPNL	Chief Engineer (LD); SE (SO&LD) – Fax- 0141-2740920
UPRVUNL	DGM (TOM), 0522-2287861
UJVNL	General Manager Engineering: 0135-2761485, fax- 0135-2761549
NPCIL	(i) Station Director, NAPS; Fax. 05734-222177.(ii) Sr. Manager (Transmission), NPCILFax.-022-25563350
JPPVL	Sh. Suresh Chandra, Director, Fax- 0120-4516201/4609464/4609496
Jhajjar PL	Sh. Goutam Biswas, GM (Production), 01251-270155.