

ANTICIPATED POWER REQUIREMENT Vs AVAILABILITY FOR THE YEAR 2017-18

(All figures in MW net)

	Apr-17	May-17	Jun-17	Jul-17	Aug-17	Sep-17	Oct-17	Nov-17	Dec-17	Jan-18	Feb-18	Mar-18
CHANDIGARH												
Peak Demand	280	390	390	380	370	340	300	200	240	260	230	220
Peak Availability	274	363	365	348	361	330	281	187	221	245	220	211
Surplus/Deficit (-)	-6	-27	-25	-32	-9	-10	-19	-13	-19	-15	-10	-9
Surplus/Deficit %	-2.1	-6.9	-6.4	-8.4	-2.4	-2.9	-6.3	-6.5	-7.9	-5.8	-4.3	-4.1
DELHI												
Peak Demand	5000	6560	6400	6500	6000	5600	5600	3700	4200	4400	4000	4000
Peak Availability	5952	6657	6492	6550	6280	6378	6321	5147	5573	5782	5533	5401
Surplus/Deficit (-)	952	97	92	50	280	778	721	1447	1373	1382	1533	1401
Surplus/Deficit %	19.0	1.5	1.4	0.8	4.7	13.9	12.9	39.1	32.7	31.4	38.3	35.0
HARAYANA												
Peak Demand	7740	8430	9340	9740	9890	9610	8490	7040	6870	7370	6950	7000
Peak Availability	8432	8351	8880	8821	8849	8766	7922	7835	7951	7911	7889	7941
Surplus/Deficit (-)	692	-79	-460	-919	-1041	-844	-568	795	1081	541	939	941
Surplus/Deficit %	8.9	-0.9	-4.9	-9.4	-10.5	-8.8	-6.7	11.3	15.7	7.3	13.5	13.4
HIMACHAL PRADESH												
Peak Demand	1470	1420	1410	1450	1430	1410	1440	1480	1570	1550	1540	1520
Peak Availability	2065	2333	2177	2063	2124	2187	2067	1860	1803	1623	1620	1698
Surplus/Deficit (-)	595	913	767	613	694	777	627	380	233	73	80	178
Surplus/Deficit %	40.5	64.3	54.4	42.3	48.5	55.1	43.5	25.7	14.8	4.7	5.2	11.7
JAMMU & KASHMIR												
Peak Demand	2510	2650	2520	2450	2410	2590	2600	2550	2650	2770	2720	2550
Peak Availability	2177	2143	2163	2207	2198	2273	2180	2229	2357	2393	2385	2279
Surplus/Deficit (-)	-333	-507	-357	-243	-212	-317	-420	-321	-293	-377	-335	-271
Surplus/Deficit %	-13.3	-19.1	-14.2	-9.9	-8.8	-12.2	-16.2	-12.6	-11.1	-13.6	-12.3	-10.6
PUNJAB												
Peak Demand	6700	8520	11600	12130	12060	11170	8910	5790	6420	6370	6840	6670
Peak Availability	7175	9427	11136	11465	11502	10606	9370	8171	8041	8125	8624	8992
Surplus/Deficit (-)	475	907	-464	-665	-558	-564	460	2381	1621	1755	1784	2322
Surplus/Deficit %	7.1	10.6	-4.0	-5.5	-4.6	-5.0	5.2	41.1	25.2	27.6	26.1	34.8
RAJASTHAN												
Peak Demand	9640	10390	10610	9880	10180	11490	9650	10200	10950	10920	10760	11320
Peak Availability	11839	11528	10972	10671	11027	12274	11479	12193	11803	12137	12277	12382
Surplus/Deficit (-)	2199	1138	362	791	847	784	1829	1993	853	1217	1517	1062
Surplus/Deficit %	22.8	11.0	3.4	8.0	8.3	6.8	19.0	19.5	7.8	11.1	14.1	9.4
UTTAR PRADESH												
Peak Demand	16390	17160	17220	17170	16830	17720	16880	13030	16780	17080	16330	15210
Peak Availability	16185	17313	17821	17786	17866	17660	16820	16359	16483	16575	16904	16984
Surplus/Deficit (-)	-205	153	601	616	1036	-60	-60	3329	-297	-505	574	1774
Surplus/Deficit %	-1.3	0.9	3.5	3.6	6.2	-0.3	-0.4	25.5	-1.8	-3.0	3.5	11.7
UTTARAKHAND												
Peak Demand	1930	2110	2050	2220	2070	2060	1960	1960	2240	2210	2080	1930
Peak Availability	2002	2082	1973	2107	2070	2101	1850	1895	2167	2156	2014	1860
Surplus/Deficit (-)	72	-28	-77	-113	0	41	-110	-65	-73	-54	-66	-70
Surplus/Deficit %	3.7	-1.3	-3.8	-5.1	0.0	2.0	-5.6	-3.3	-3.3	-2.4	-3.2	-3.6
TOTAL NORTHERN REGION												
Peak Demand	50600	54000	56800	55400	56800	56800	51800	43800	48300	47800	45400	48000
Peak Availability	54000	58500	59400	60000	60600	57300	53300	50500	52400	53000	53100	54500
Surplus/Deficit (-)	3400	4500	2600	4600	3800	500	1500	6700	4100	5200	7700	6500
Surplus/Deficit %	6.7	8.3	4.6	8.3	6.7	0.9	2.9	15.3	8.5	10.9	17.0	13.5

ANTICIPATED ENERGY REQUIREMENT Vs AVAILABILITY FOR THE YEAR 2017-18

(All figures in Mu/Day net)

	Apr-17	May-17	Jun-17	Jul-17	Aug-17	Sep-17	Oct-17	Nov-17	Dec-17	Jan-18	Feb-18	Mar-18
CHANDIGARH												
Requirement	4.61	5.79	6.40	6.06	5.67	5.64	4.15	3.34	3.49	3.81	3.49	3.60
Availability	4.44	5.62	6.20	5.82	5.67	5.61	4.15	3.29	3.35	3.62	3.43	3.45
Surplus/Deficit (-)	-0.17	-0.17	-0.20	-0.24	0.00	-0.03	0.00	-0.04	-0.14	-0.19	-0.06	-0.15
Surplus/Deficit %	-3.69	-2.94	-3.13	-3.92	-0.07	-0.58	-0.12	-1.30	-4.01	-5.03	-1.68	-4.07
DELHI												
Requirement	92.89	110.15	121.01	113.48	110.61	108.81	89.26	60.92	60.68	65.14	63.68	66.93
Availability	105.07	121.60	128.66	121.43	123.54	121.66	107.98	79.56	86.09	93.19	85.48	85.02
Surplus/Deficit (-)	12.17	11.45	7.64	7.95	12.93	12.85	18.71	18.65	25.41	28.05	21.80	18.09
Surplus/Deficit %	13.11	10.39	6.32	7.01	11.69	11.81	20.97	30.61	41.87	43.07	34.23	27.03
HARAYANA												
Requirement	124.41	139.06	166.20	179.76	174.98	179.72	141.59	103.90	121.46	119.61	122.05	114.16
Availability	140.11	152.63	175.10	188.94	182.53	191.93	158.75	115.54	135.30	134.87	135.25	129.64
Surplus/Deficit (-)	15.69	13.57	8.90	9.17	7.55	12.21	17.15	11.65	13.84	15.26	13.20	15.48
Surplus/Deficit %	12.61	9.76	5.36	5.10	4.31	6.80	12.11	11.21	11.39	12.76	10.82	13.56
HIMACHAL PRADESH												
Requirement	25.50	26.05	27.10	27.30	27.30	25.30	26.05	27.00	27.30	27.30	27.20	26.80
Availability	30.22	39.07	43.53	45.81	47.68	37.44	32.56	29.78	28.69	28.64	28.58	30.46
Surplus/Deficit (-)	4.72	13.02	16.43	18.51	20.38	12.14	6.51	2.78	1.39	1.34	1.38	3.66
Surplus/Deficit %	18.51	49.98	60.63	67.80	74.65	47.98	24.99	10.30	5.11	4.89	5.08	13.64
JAMMU & KASHMIR												
Requirement	50.11	52.20	50.31	40.51	43.98	47.53	48.55	52.10	54.00	53.65	54.64	49.11
Availability	37.98	40.52	43.99	32.15	38.35	38.19	37.98	42.31	42.66	44.66	46.23	39.65
Surplus/Deficit (-)	-12.13	-11.68	-6.32	-8.36	-5.64	-9.33	-10.57	-9.79	-11.33	-8.99	-8.41	-9.45
Surplus/Deficit %	-24.20	-22.37	-12.56	-20.64	-12.81	-19.64	-21.77	-18.78	-20.99	-16.75	-15.40	-19.25
PUNJAB												
Requirement	118.45	162.62	210.08	224.85	217.05	220.32	148.51	99.17	108.03	101.24	108.94	116.56
Availability	130.55	165.94	214.08	221.54	218.08	216.64	149.55	121.65	117.01	114.23	118.17	122.32
Surplus/Deficit (-)	12.10	3.33	4.00	-3.31	1.03	-3.68	1.05	22.48	8.97	12.99	9.23	5.76
Surplus/Deficit %	10.21	2.05	1.90	-1.47	0.48	-1.67	0.70	22.67	8.31	12.84	8.48	4.94
RAJASTHAN												
Requirement	186.25	205.82	212.87	183.39	168.37	207.85	188.27	200.06	208.23	207.06	210.06	207.97
Availability	198.76	217.61	216.29	204.95	193.47	221.57	209.23	209.03	212.59	218.33	219.29	220.63
Surplus/Deficit (-)	12.51	11.78	3.43	21.56	25.10	13.72	20.96	8.97	4.37	11.27	9.23	12.67
Surplus/Deficit %	6.72	5.72	1.61	11.75	14.91	6.60	11.13	4.48	2.10	5.44	4.39	6.09
UTTAR PRADESH												
Requirement	322.70	335.20	360.20	324.80	322.50	363.80	317.50	281.60	293.00	303.60	298.90	324.50
Availability	344.72	380.43	391.72	389.74	391.79	386.85	369.00	356.47	363.40	364.77	371.66	373.76
Surplus/Deficit (-)	22.02	45.23	31.52	64.94	69.29	23.05	51.50	74.87	70.40	61.17	72.76	49.26
Surplus/Deficit %	6.82	13.49	8.75	19.99	21.49	6.34	16.22	26.59	24.03	20.15	24.34	15.18
UTTARAKHAND												
Requirement	37.87	39.23	41.40	41.03	41.39	42.03	37.87	37.10	40.68	39.83	39.24	36.67
Availability	37.40	39.81	40.57	39.82	41.14	39.69	37.22	37.42	39.13	39.61	39.06	36.19
Surplus/Deficit (-)	-0.47	0.59	-0.83	-1.21	-0.25	-2.34	-0.65	0.32	-1.54	-0.23	-0.18	-0.48
Surplus/Deficit %	-1.24	1.50	-1.99	-2.95	-0.60	-5.57	-1.72	0.86	-3.80	-0.57	-0.46	-1.30
TOTAL NORTHERN REGION												
Requirement	962.80	1076.12	1195.57	1141.18	1111.85	1200.99	1001.76	865.18	916.87	921.24	928.21	946.29
Availability	1029.26	1163.23	1260.15	1250.20	1242.25	1259.58	1106.41	995.06	1028.22	1041.91	1047.16	1041.12
Surplus/Deficit (-)	66.45	87.11	64.58	109.02	130.40	58.58	104.65	129.88	111.36	120.68	118.95	94.83
Surplus/Deficit %	6.90	8.10	5.40	9.55	11.73	4.88	10.45	15.01	12.15	13.10	12.81	10.02

ANTICIPATED ENERGY REQUIREMENT Vs AVAILABILITY FOR THE YEAR 2017-18

(All figures in Mu net)

	Apr-17	May-17	Jun-17	Jul-17	Aug-17	Sep-17	Oct-17	Nov-17	Dec-17	Jan-18	Feb-18	Mar-18
CHANDIGARH												
Requirement	138	179	192	188	176	169	129	100	108	118	98	112
Availability	133	174	186	181	176	168	129	99	104	112	96	107
Surplus/Deficit (-)	-5	-5	-6	-7	0	-1	0	-1	-4	-6	-2	-5
Surplus/Deficit %	-3.69	-2.94	-3.13	-3.92	-0.07	-0.58	-0.12	-1.30	-4.01	-5.03	-1.68	-4.07
DELHI												
Requirement	2787	3415	3630	3518	3429	3264	2767	1827	1881	2019	1783	2075
Availability	3152	3770	3860	3764	3830	3650	3347	2387	2669	2889	2394	2636
Surplus/Deficit (-)	365	355	229	246	401	386	580	559	788	870	610	561
Surplus/Deficit %	13.11	10.39	6.32	7.01	11.69	11.81	20.97	30.61	41.87	43.07	34.23	27.03
HARAYANA												
Requirement	3732	4311	4986	5573	5424	5391	4389	3117	3765	3708	3417	3539
Availability	4203	4731	5253	5857	5658	5758	4921	3466	4194	4181	3787	4019
Surplus/Deficit (-)	471	421	267	284	234	366	532	349	429	473	370	480
Surplus/Deficit %	12.61	9.76	5.36	5.10	4.31	6.80	12.11	11.21	11.39	12.76	10.82	13.56
HIMACHAL PRADESH												
Requirement	765	808	813	846	846	759	808	810	846	846	762	831
Availability	907	1211	1306	1420	1478	1123	1009	893	890	888	800	944
Surplus/Deficit (-)	142	404	493	574	632	364	202	83	43	41	39	113
Surplus/Deficit %	18.51	49.98	60.63	67.80	74.65	47.98	24.99	10.30	5.11	4.89	5.08	13.64
JAMMU & KASHMIR												
Requirement	1503	1618	1509	1256	1364	1426	1505	1563	1674	1663	1530	1522
Availability	1140	1256	1320	997	1189	1146	1177	1269	1323	1384	1294	1229
Surplus/Deficit (-)	-364	-362	-190	-259	-175	-280	-328	-294	-351	-279	-236	-293
Surplus/Deficit %	-24.20	-22.37	-12.56	-20.64	-12.81	-19.64	-21.77	-18.78	-20.99	-16.75	-15.40	-19.25
PUNJAB												
Requirement	3554	5041	6302	6970	6729	6610	4604	2975	3349	3138	3050	3613
Availability	3916	5144	6422	6868	6761	6499	4636	3650	3627	3541	3309	3792
Surplus/Deficit (-)	363	103	120	-103	32	-110	32	674	278	403	259	178
Surplus/Deficit %	10.21	2.05	1.90	-1.47	0.48	-1.67	0.70	22.67	8.31	12.84	8.48	4.94
RAJASTHAN												
Requirement	5588	6381	6386	5685	5219	6236	5837	6002	6455	6419	5882	6447
Availability	5963	6746	6489	6353	5998	6647	6486	6271	6590	6768	6140	6840
Surplus/Deficit (-)	375	365	103	668	778	411	650	269	135	349	258	393
Surplus/Deficit %	6.72	5.72	1.61	11.75	14.91	6.60	11.13	4.48	2.10	5.44	4.39	6.09
UTTAR PRADESH												
Requirement	9681	10391	10806	10069	9998	10914	9843	8448	9083	9412	8369	10060
Availability	10342	11793	11752	12082	12146	11605	11439	10694	11265	11308	10406	11587
Surplus/Deficit (-)	661	1402	946	2013	2148	691	1596	2246	2182	1896	2037	1527
Surplus/Deficit %	6.82	13.49	8.75	19.99	21.49	6.34	16.22	26.59	24.03	20.15	24.34	15.18
UTTARAKHAND												
Requirement	1136	1216	1242	1272	1283	1261	1174	1113	1261	1235	1099	1137
Availability	1122	1234	1217	1235	1275	1191	1154	1123	1213	1228	1094	1122
Surplus/Deficit (-)	-14	18	-25	-37	-8	-70	-20	10	-48	-7	-5	-15
Surplus/Deficit %	-1.24	1.50	-1.99	-2.95	-0.60	-5.57	-1.72	0.86	-3.80	-0.57	-0.46	-1.30
TOTAL NORTHERN REGION												
Requirement	28884	33360	35867	35377	34467	36030	31055	25955	28423	28558	25990	29335
Availability	30878	36060	37805	38756	38510	37787	34299	29852	31875	32299	29320	32275
Surplus/Deficit (-)	1994	2701	1937	3380	4042	1757	3244	3896	3452	3741	3330	2940
Surplus/Deficit %	6.90	8.10	5.40	9.55	11.73	4.88	10.45	15.01	12.15	13.10	12.81	10.02

केंद्र / Station	Unit	केंद्र क्षमता Station Capacity (MW)	वार्षिक आउटेज योजना के अनुसार अनुरक्षण शेड्यूल Maintenance Schedule as per Annual Outage Planning			अभ्युक्तियों Remarks
			से / From	तक / To	दिनों की संख्या No of Days	
Singrauli STPS	1	200				
	2	200	29.05.2017	01.06.2017	3	Boiler License Renewal Boiler OH etc
	3	200	01.07.2017	25.07.2017	25	Boiler+Turbine+Gen+ESP bellows etc.
	4	200	01.08.2017	04.09.2017	35	
	5	200				
	6	500	28.10.2017	26.11.2017	30	Boiler OH/LPT
	7	500	10.09.2017	14.10.2017	35	Boiler OH
Rihand-I STPS	1	500				
	2	500				
Rihand-II	3	500	09.05.2017	12.05.2017	3	BLR Boiler LP Turbine GRP Relay Replacement
	4	500	13.11.2017	12.12.2017	30	
Rihand-III	5	500				
	6	500	12.05.2017	10.06.2017	30	Boiler & Aux Inspection of LPT outer 2 stage blade OH of HP/IP SV/CV & TG Gov System
Unchahar -I faridabad (GPS)	1	210	20.09.2017	14.10.2017	25	Boiler OH Turbine Gen ESP R&M DDCIMS Turbine Bearing Inspection
	2	210				
Unchahar -II	3	210				
	4	210	01.07.2017	25.07.2017	25	BoilerOH LPT Gen
Unchahar -III	5	210	25.04.2017	19.05.217	25	Boiler Turbine Gen
Tanda TPS (CSGS Dedicated to UP)	1	110	01.04.2017	05.05.2017	35	GEN HP IP LPT Turbine Gen Rotor to be Changed
	2	110				
	3	110	01.07.2017	25.07.2017	25	Boiler
	4	110				
Dadri NCTPS	1	210	10.05.2017	12.05.2017	3	BLR
	2	210	01.03.2018	20.03.2018	20	Boiler OH LPT Gen RLA
			23.12.2017	25.12.2017	3	
	3	210	14.10.2017	16.10.2017	3	BLR
	4	210	17.08.2017	10.09.2017	25	Boiler OH+IPT+ LPT+ Gen O/H
	5	490	17.04.2017	21.04.2017	5	BLR
6	490	01.11.2017	05.12.2017	35	Capital + Gen.	
BTSP (CSGS Dedicated to Delhi)	1	95				
	2	95				
	3	95				
	4	210				
	5	210				

केंद्र / Station	Unit	केंद्र क्षमता Station Capacity (MW)	वार्षिक आउटेज योजना के अनुसार अनुरक्षण शेड्यूल Maintenance Schedule as per Annual Outage Planning			व्यक्तियों Remarks
			से / From	तक / To	दिनों की संख्या No of Days	
Anta	GT 1	88.7	20.07.2017	25.07.2017	6	12000VOH Inspection
			20.01.2018	23.01.2018	4	
	GPS	88.7	01.06.2017	04.06.2017	4	12000 VOH Inspection
	GT 3	88.7	01.07.2017	04.07.2017	4	12000 VOH Inspection
	ST G	153.2	01.01.2018	06.01.2018	6	12000 VOH Inspection
			16.03.2017	14.04.2017	30	Bearing Inspection
Auriya	GT 1	111.19	09.05.2017	09.05.2017	1	WHRB License Renewal Turbine Inspection
			22.10.2017	05.11.2017	15	
	GPS	111.19	20.04.2017	01.05.2017	12	Duct repair WHRB License Renewal
			10.07.2017	10.07.2017	1	
	GT 3	111.19	26.06.2017	27.06.2017	2	WHRB License Renewal AFR
			13.12.2017	15.12.2017	3	
	GT 4	111.19	23.02.2018	23.02.2018	1	WHRB License Renewal
	ST 1	109.3	20.04.2017	01.05.2017	12	GT Replacement
	ST 2	109.3				
Dadri	GT 1	130.19	20.02.2017	10.04.2017	50	Boiler License Renewal 8000EOH Inspection Fleme Tube Inspection AFR Compressor Washing
			24.04.2017	25.04.2017	2	
			15.08.2017	21.08.2017	7	
			01.11.2017	10.11.2017	10	
			02.01.2018	02.01.2018	1	
	GPS	130.19	20.02.2017	10.04.2017	50	Boiler License Renewal 8000EOH Inspection Fleme Tube Inspection AFR Compressor Washing
			20.06.2017	21.06.2017	2	
			22.08.2017	26.08.2017	5	
			08.02.2018	14.02.2018	7	
			02.03.2018	02.03.2018	1	
	GT 3	130.19	02.07.2017	06.07.2017	5	4000 EOH Inspection Major+gen+C and I R&M
			15.01.2018	18.02.2018	35	
	GT 4	130.19	20.06.2017	21.06.2017	2	Boiler License Renewal 8000EOH Inspection etc
		11.08.2017	15.08.2017	5		
		15.01.2018	18.02.2018	35		
ST 1	154.51	20.02.2017	10.04.2017	50	Annual Inspection+C&I R&M	
ST 2	154.51	15.01.2018	18.02.2018	35		
Faridabad (GPS) (CSGS Dedicated to Haryana)	GT 1	137.758	15.05.2017	19.05.2017	5	Major Inspection AFR
			15.12.2017	19.12.2017	5	
	GT 2	137.758	20.03.2017	03.05.2017	45	Major Inspection Gen rewinding Minor Inspection AFR
			01.01.2018	05.01.2018	5	
	ST 2	156.08				

केंद्र / Station	Unit	केंद्र क्षमता Station Capacity (MW)	वार्षिक आउटेज योजना के अनुसार अनुरक्षण शेड्यूल Maintenance Schedule as per Annual Outage Planning			व्यक्तियों Remarks
			से / From	तक / To	दिनों की संख्या No of Days	
IGSTPP, Jhajjar	1	500	23.01.2018	25.01.2018	3	BLR
	2	500	03.05.2017	05.05.2017	3	BLR
	3	500				
NAPS	1	220				
	2	220	01.09.2017	30.09.2017	30	Biennial Shutdown
RAPS - A(CSGS Dedicated to Raj)	2	200				
RAPS - B	3	220				
	4	220	01.10.2017	10.11.2017	41	BSD
RAPS - C	5	220				
	6	220	01.11.2017	10.12.2017	41	BSD
NHPC Baira Siul (3x60)	1	60	13.01.2018	11.02.2018	30	CM
	2	60	10.11.2017	29.11.2017	20	AM
	3	60	12.12.2017	31.12.2017	20	AM
Salal (6x115)	1	115	20.12.2017	29.03.2018	100	CM
	2	115	01.10.2017	09.11.2017	40	AM
	3	115	10.11.2017	19.12.2017	40	AM
	4	115	29.01.2018	09.03.2018	40	AM
	5	115	01.10.2017	28.01.2018	120	CM
	6	115	20.12.2017	28.01.2018	40	AM
Chamera - I (3x180)	1	180	05.12.2017	25.12.2017	21	AM
	2	180	27.12.2017	16.01.2018	21	AM
	3	180	18.01.2018	07.02.2018	21	AM
Chamera - II (3x100)	1	100	15.11.2017	29.11.2017	15	AM
	2	100	01.12.2017	15.12.2017	15	AM
	3	100	18.12.2017	16.01.2018	30	CM
Chamera - III (3x77)	1	77	01.02.2018	28.02.2018	28	CM
	2	77	02.01.2018	16.01.2018	15	AM
	3	77	17.01.2018	31.01.2018	15	AM
Uri (4x120)	1	120	05.12.2017	04.01.2018	31	CM
	2	120	10.01.2018	08.02.2018	30	CM
	3	120	26.10.2017	10.11.2017	16	AM
	4	120	16.11.2017	30.11.2017	15	AM
Tanakpur (3x31.4)	1	31.4	15.11.2017	15.12.2017	31	AM
	2	31.4	21.12.2017	20.01.2018	30	AM
	3	31.4	26.01.2018	15.05.2018	110	CM
Uri II (4x60)	1	60	01.11.2017	20.11.2017	20	AM
	2	60	24.11.2017	13.12.2017	20	AM
	3	60	17.12.2017	05.01.2018	20	AM
	4	60	09.01.2018	28.01.2018	20	AM
Dhauliganga (4x70)	1	70	21.12.2017	09.01.2018	20	AM
	2	70	15.01.2018	03.02.2018	20	AM
	3	70	17.10.2017	15.11.2017	30	AM
	4	70	18.11.2017	17.12.2017	30	AM
Dulhasti (3x130)	1	130	01.12.2017	20.12.2017	20	AM
	2	130	22.12.2017	10.01.2018	20	AM
	3	130	12.01.2018	31.01.2018	20	AM
PARBATI-III (4x130)	1	130	25.01.2018	18.02.2018	25	AM
	2	130	29.12.2017	22.01.2018	25	AM
	3	130	02.12.2017	26.12.2017	25	AM
	4	130	16.10.2017	29.11.2017	45	CM
SEWA -- II (3x40)	1	40	15.11.2017	04.12.2017	21	AM
	2	40	06.12.2017	26.12.2017	21	AM
	3	40	27.12.2017	16.01.2018	21	AM
BBMB Bhakra (L)	1	108	25.01.2018	18.02.2018	25	AM
	2	126	14.11.2017	05.12.2017	22	AM
	3	108	25.09.2017	14.10.2017	20	AM
	4	126	24.04.2017	10.06.2017	48	Runner Modification by Hitachi Ltd if results of modified runner of unit 2 found satisfactory joint inspection tentatively during March 2017 after 6400hrs of running For replacement of generator shaft and spider
	5	126	21.06.2016	31.03.2018	649	

केंद्र / Station	Unit	केंद्र क्षमता Station Capacity (MW)	वार्षिक आउटेज योजना के अनुसार अनुरक्षण शेड्यूल Maintenance Schedule as per Annual Outage Planning			व्यक्तियों Remarks	
			से / From	तक / To	दिनों की संख्या No of Days		
Bhakra (R)	6	157	03.01.2018	23.01.2018	21	AM	
	7	157	23.10.2017	11.11.2017	20	AM	
			20.02.2018	11.03.2018	20	AM	
	8	157	16.10.2017	23.03.2018	159	CM	
	9	157	06.12.2017	26.12.2017	21	AM	
	10	157	12.03.2018	31.03.2018	20	AM	
Ganguwal	1	27.99	19.06.2017	25.06.2017	7		
			25.09.2017	28.09.2017	4	Half yearly maintenance quarterly mtc.annual mtc.etc	
			18.12.2017	27.12.2017	10		
	2	24.20	26.03.2018	29.03.2018	4		
			01.04.2017	30.09.2017	183		
			28.12.2017	31.12.2017	4	RM Works half yearly maintenance quarterly mtc.	
	3	24.20	12.03.2018	18.03.2018	7		
			19.04.2017	28.04.2017	10		
			25.07.2017	28.07.2017	4	Half yearly maintenance quarterly mtc.annual mtc.etc	
	Kotla	1	28.94	23.10.2017	29.10.2017	7	
				23.01.2017	26.01.2017	4	
				22.05.2017	25.05.2017	4	
2		24.20	21.08.2017	26.08.2017	6	Half yearly maintenance quarterly mtc.annual mtc.etc	
			15.11.2017	18.11.2017	4		
			12.02.2018	21.02.2018	10		
3		24.20	29.05.2017	04.06.2017	7		
			28.08.2017	31.08.2017	4		
			20.11.2017	29.11.2017	10	Half yearly maintenance quarterly mtc.annual mtc.etc	
			22.02.2018	25.02.2018	4		
			01.04.2017	30.09.2017	183		
			13.12.2017	16.12.2017	4		
			19.03.2018	25.03.2018	7	RM Works half yearly maintenance quarterly mtc.	
Dehar	1	165	05.03.2018	24.03.2018	20	AM	
	2	165	11.01.2018	30.01.2018	20	AM	
	3	165	23.10.2017	11.11.2017	20	AM	
	4	165	08.01.2018	07.04.2018	90	CM	
	5	165	03.10.2017	30.12.2017	90	CM	
	6	165	20.11.2017	09.12.2017	20	AM	
Pong	1	66	03.04.2017	17.04.2017	15		
			02.10.2017	08.10.2017	7	AM half yearly mtc etc.	
			03.03.2018	02.04.2018	30		
	2	66	01.04.2017	01.05.2017	31	Capital mtc & replacement of governor & half yearly maintenance	
			09.10.2017	15.10.2017	7		
	3	66	18.04.2017	02.05.2017	15	AM half yearly mtc etc.	
			16.10.2017	22.10.2017	7		
	4	66	23.10.2017	29.11.2017	38	Half yearly mtc etc.	
	5	66	03.05.2017	17.05.2017	15	AM half yearly mtc etc.	
			30.11.2017	06.12.2017	7		
	6	66	07.11.2017	13.11.2017	7	Half yearly mtc	

केंद्र / Station	Unit	केंद्र क्षमता Station Capacity (MW)	वार्षिक आउटेज योजना के अनुसार अनुरक्षण शेड्यूल Maintenance Schedule as per Annual Outage Planning			व्यक्तियों Remarks
			से / From	तक / To	दिनों की संख्या No of Days	
Rampur (6x68.67)	1	68.67	01.12.2017	15.12.2017	15	Annual Planned Maintenance
	2	68.67	16.12.2017	30.12.2017	15	Annual Planned Maintenance
	3	68.67	31.12.2017	14.01.2018	15	Annual Planned Maintenance
	4	68.67	15.01.2018	29.01.2018	15	Annual Planned Maintenance
	5	68.67	30.01.2018	13.02.2018	15	Annual Planned Maintenance
	6	68.67	14.02.2018	28.02.2018	15	Annual Planned Maintenance
Nathpa-Jhakri (6x250)	1	250	01.12.2017	15.12.2017	15	Annual Planned Maintenance
	2	250	16.12.2017	30.12.2017	15	Annual Planned Maintenance
	3	250	31.12.2017	14.01.2018	15	Annual Planned Maintenance
	4	250	15.01.2018	29.01.2018	15	Annual Planned Maintenance
	5	250	30.01.2018	13.02.2018	15	Annual Planned Maintenance
	6	250	14.02.2018	28.02.2018	15	Annual Planned Maintenance
Tehri HPP	1	250	01.04.2017	30.04.2017	30	AM
	2	250	01.03.2018	31.03.2018	31	AM
	3	250	01.06.2017	30.06.2017	30	AM
	4	250	01.05.2017	31.05.2017	31	AM
Koldam HEP (NTPC)	1	200	06.01.2018	11.01.2018	6	Annual Inspection
	2	200	19.12.2017	30.12.2017	12	Annual Inspection+ Bearing jobs
	3	200	14.01.2018	19.01.2018	6	Annual Inspection
	4	200	28.01.2018	02.02.2018	6	Annual Inspection
Koteshwar HEP	1	100	16.11.2017	30.12.2017	46	AM
	2	100	01.04.2017	30.04.2017	30	AM
	3	100	16.05.2017	30.06.2017	46	AM
	4	100	01.10.2017	15.11.2017	46	AM

केंद्र / Station	Unit	केंद्र क्षमता Station Capacity (MW)	वार्षिक आऊटेज योजना के अनुसार अनुरक्षण शेड्यूल Maintenance Schedule as per Annual Outage Planning			अभ्युक्तियों Remarks
			से / From	तक / To	दिनों की संख्या No of Days	
Delhi GTs (6x30+3x34)	1	30	01.09.2017	30.09.2017	30	Major Inspection
	2	30				
	3	30				
	4	30				
	5	30				
	6	30				
	ST HRSG-1	15	01.09.2017	20.09.2017	20	Major Inspection
	ST HRSG-2	15				
	ST HRSG-3	15				
	ST HRSG-4	15				
	ST HRSG-5	15				
	ST HRSG-6	15				
RTPS 2X67.5	1	67.5	01.09.2017	20.09.2017	20	Major Inspection
	2	67.5				
PRAGATI - I	1-GT	104	01.10.2017	20.10.2017	20	HGPI & Boiler Inspection
	2-GT	104				
	3-ST	122				
PRAGATI - III BAWANA	1-GT	216	01.02.2018	28.02.2018	28	Generator Minor Inspection
	2-GT	216				
	3-GT	216	01.10.2017	10.10.2017	10	Combustion Inspection
	4-GT	216				
	1-ST	253.6	10.03.2018	19.03.2018	10	Combustion Inspection
	2-ST	253.6				

केंद्र / Station	Unit	केंद्र क्षमता Station Capacity (MW)	वार्षिक आऊटेज योजना के अनुसार अनुरक्षण शेड्यूल Maintenance Schedule as per Annual Outage Planning			अभ्युक्तियों Remarks
			से / From	तक / To	दिनों की संख्या No of Days	
RITHALA NDPL	1-GT 2-GT 3-ST	31.6 31.6 31.6				
Haryana PTPS (4x110 + 2x210 + 2x250)	1 2 3 4 5 6 7 8	110 110 110 110 210 210 250 250	21.11.2017	01.04.2018	130	Capital Overhaul
			20.07.2017	02.09.2017	45	Capital Overhauling
DCRTPP Yamuna Nagar (2x300)	1 2	300 300	11.11.2017	09.01.2018	60	Capital Overhauling and rehabilitation of ESP's to meet new environmental norms fixed by MOEF
			12.01.2018	12.03.2018	60	Capital Overhauling and rehabilitation of ESP's to meet new environmental norms fixed by MOEF
RGTPP HISSAR (2x600)	1 2	600 600	16.10.2017	19.11.2017	35	Capital Overhaul
CLP Jhhajhar	1 2	660 660	01.11.2017	15.11.2017	15	AOH Capital Overhaul
			13.03.2018	11.05.2018	60	
			01.04.2017	29.04.2017	29	Capital Overhaul

केंद्र / Station	Unit	केंद्र क्षमता Station Capacity (MW)	वार्षिक आउटेज योजना के अनुसार अनुरक्षण शेड्यूल Maintenance Schedule as per Annual Outage Planning			व्यक्तियों Remarks
			से / From	तक / To	दिनों की संख्या No of Days	
Rajasthan KTPS (2x110+4x210)	1	110	25.04.2017	09.05.2017	15	Annual Overhaul
	2	110	25.05.2017	08.06.2017	15	Annual Overhaul
	3	210	09.06.2017	13.07.2017	35	Annual Capital Overhaul
	4	210	10.05.2017	24.05.2017	15	Annual Overhaul
	5	210	10.04.2017	24.04.2017	15	Annual Overhaul
	6	195	29.07.2017	12.08.2017	15	Annual Overhaul
	7	195	14.07.2017	28.07.2017	15	Annual Overhaul
RAMGARH GAS CAPP	1-GT	35.5				
	2-GT	37.5	01.05.2017	15.05.2017	15	HGPI
	3-GT	110	01.09.2017	15.09.2017	15	HGPI
	1-ST	37.5	01.06.2017	22.06.2017	22	Capital OH
	2-ST	50				
SURATGARH TPS	1	250	01.12.2017	21.12.2017	21	Annual O/H
	2	250	02.01.2018	22.01.2018	21	Annual O/H
	3	250	19.08.2017	08.09.2017	21	Annual O/H
	4	250	01.02.2018	21.02.2018	21	Annual O/H
	5	250	16.06.2017	15.07.2017	30	Annual O/H
	6	250	16.01.2018	05.02.2018	21	Annual O/H
DHOLPUR GAS CAPP	1-GT	110	01.09.2017	04.11.2017	65	Major O/H
	2-GT	110				
	3-ST	110	01.09.2017	20.10.2017	50	Major O/H
Kalisindh TPP	1	600	07.07.2017	21.07.2017	15	Annual O/H
	2	600	07.08.2017	21.08.2017	15	Annual O/H
GIRAL	1	125				
	2	125				
CHHABRA TPS	1	250	15.06.2017	14.07.2017	30	Annual Mtc. & O/H of unit NFT & MPI of Turbine
	2	250	07.07.2017	21.07.2017	30	Annual Overhaul
	3	250	16.08.2017	24.09.2017	21	Annual Overhaul and LP Turbine, Bearing & Generator Inspection.
	4	250	08.08.2017	22.08.2017	30	Annual O/H nad replacement of FD-14 Valve
	5	660				
BARSINGAR LTPS NLC	1	125	05.07.2017	03.08.2017	30	Annual Maintenance of boiler & statutory inspectory
	2	125	05.04.2017	04.05.2017	30	Annual Maintenance of boiler & statutory inspectory
KAWAI (adani-mundra)	7	660				
	8	660	01.12.2017	09.01.2018	40	
	9	660				
Adani-Rajasthan	1	660	01.06.2017	25.06.2017	25	
	2	660				
RAJWEST Power (8x135)	1	135	12.04.2017	19.04.2017	8	Refractory Mtc.
			15.07.2017	27.07.2017	12	
	2	135	07.03.2018	14.03.2018	8	BLR, Refractory mtc & boiler inspection
			21.07.2017	28.07.2017	8	
	3	135	15.03.2018	30.03.2018	16	BLR, Refractory mtc & boiler inspection
			02.06.2017	09.06.2017	8	
	4	135	27.12.2017	03.01.2018	8	BLR, Refractory mtc & boiler inspection
			15.02.2018	22.02.2018	8	
	5	135	24.08.2017	31.08.2017	8	BLR, Refractory mtc & boiler inspection
			12.11.2017	19.11.2017	8	
	6	135	23.02.2018	02.03.2018	8	BLR, Refractory mtc & boiler inspection
			28.04.2017	05.05.2017	8	
	7	135	01.09.2017	25.09.2017	25	BLR, Refractory mtc & boiler inspection
			28.12.2017	04.01.2018	8	
	8	135	06.05.2017	13.05.2017	8	BLR, Refractory mtc & boiler inspection
			19.08.2017	26.08.2017	8	
8	135	22.11.2017	29.11.2017	8	BLR, Refractory mtc & boiler inspection	
		01.12.2017	25.12.2017	25		
8	135	27.05.2017	03.06.2017	8	BLR, Refractory mtc & boiler inspection	
		12.02.2018	27.02.2018	16		
8	135	30.04.2017	07.05.2017	8	BLR, Refractory mtc & boiler inspection	
		24.10.2017	08.11.2017	16		

केंद्र / Station	Unit	केंद्र क्षमता Station Capacity (MW)	वार्षिक आउटेज योजना के अनुसार अनुरक्षण शेड्यूल Maintenance Schedule as per Annual Outage Planning			व्यक्तियों Remarks	
			से / From	तक / To	दिनों की संख्या No of Days		
UPPCL ANPARA (3x210+2x500)	1	210	05.07.2017	22.07.2017	18	Mini OH	
	2	210	01.04.2017	30.04.2017	30	OH	
	3	210	14.01.2018	31.01.2018	18	Mini OH	
	4	500	20.10.2017	03.12.2017	45	OH	
	5	500	14.03.2018	31.03.2018	18	Mini OH	
	6	500	01.10.2017	18.10.2017	18	Mini OH	
OBRA (4x40+3x94+5x200) (4x40+3x94+5x200)	1	50					
	2	50					
	6	94					
	7	94	10.12.2017	27.12.2017	18	Mini OH	
	8	94					
	9	200	11.02.2018	28.02.2018	18	Mini OH	
	10	200	10.11.2017	27.11.2017	18	Mini OH	
	11	200	01.03.2018	18.03.2018	18	Mini OH	
	12	200					
	13	200					
	PARICHHA (2x110+2x210)	1	110				
		2	110	10.04.2017	27.04.2017	18	Mini OH
		3	210	01.01.2018	30.01.2018	30	OH
4		210	20.01.2018	18.02.2018	30	OH	
5		250	01.02.2018	18.02.2018	18	Mini OH	
6		250	20.02.2018	05.04.2018	45	OH	
PANKI (1x32+2x105)	3	105					
	4	105					
H'GANJ (2x40+2x55+2x60+1x105+2x250)	5	60					
	7	105	01.09.2017	30.09.2017	30	OH	
	8	250	01.04.2017	30.04.2017	30	OH	
	9	250	10.12.2017	27.12.2017	18	Mini OH	
ROSA TPS (IPP) (3x300)	1	300					
	2	300					
	3	300	15.12.2017	14.02.2018	60	OH	
	4	300	01.11.2017	22.11.2017	22	Boiler OH	
ANPARA - C(IPP) LANCO	1	600					
	2	600	15.11.2017	05.12.2017	21	Annual Boiler OH	